



PUBLIC WORKS REPORT May 2026

WATER:

In the month of May, the water system operated in accordance with TECQ regulations. May has been a fairly slow month for overall water usage. The heavy rainfall has kept demand low. Our crews have focused on meter repairs, and the usual daily operation on water plants. Yearly samples for TCEQ were taken for the water systems of Learners and Lakes of Aledo.

WORK ORDERS

Miscellaneous	1	Meter Accuracy	0
Water Quality	0	Low Pressure	0
Meter Swap	0	Leak	0
Occupant Change	2	Information	1
Repair	20	Disconnect	0
Connect	0	Cut off	0
Reinstate	1	Meter read	0
		TOTAL	23

Automated Meter Leak Notifications

54

Ryan Berry Water/Wastewater Superintendent



PUBLIC WORKS WASTEWATER REPORT

May 2026

In the month of May, the wastewater plant maintained TCEQ standards. We received several odor complaints in May. The smell is caused by the high amount of rainfall. When water infiltrates the collection system, the pipes are effectively flushed out. The result is a bacterium that can cause odor. The water quality was not effected, but the odor can take a week or two for the plant to adjust. Our crews have done a hydrogen peroxide treatment to the collection system to help combat odor.

Repairs to wastewater system:

Hydrogen Peroxide treatment

Gallons pumped to Split Rail:

.976 MGD

A handwritten signature in black ink, appearing to be "J. B. B.", written over a horizontal line.

Water/Water Superintendent