



PUBLIC WORKS REPORT June 2026

WATER:

In the month of June the water system operated in accordance with TECQ regulations. In June the water demand for the city has increased. Our water system is keeping up with demands. The water plants have been able to keep pace with the overall systems usage. On the 100 block of Lakeview drive, Town of Annetta crew members were able to locate and repair a leak on a service line feeding two residences. Ongoing repairs to the meter system continue.

WORK ORDERS

Miscellaneous	3	Meter Accuracy	0
Water Quality	0	Low Pressure	0
Meter Swap	0	Leak	0
Occupant Change	4	Information	0
Repair	14	Disconnect	0
Connect	1	Cut off	1
Reinstate	1	Meter read	0
		TOTAL	24

Automated Meter Leak Notifications

61

Ryan Berry Water/Wastewater Superintendent



PUBLIC WORKS WASTEWATER REPORT

June 2026

In the month of June, the wastewater plant maintained TCEQ standards. In the 100 block of Rolling Springs, we received a complaint for a sewer backing up. We had the line inspected with a camera. The footage showed fiber optic cables ran through the cities service lint to the house. AT&T was called, they excavated the line and Town of Annetta crew made the necessary repairs.

Repairs to wastewater system:

Repair to service line on Rolling Spring

Gallons pumped to Split Rail:

.988 MGD



Water/Water Superintendent