



PUBLIC WORKS REPORT July 2026

WATER:

In the month of July the water system operated in accordance with TECQ regulations. In July the water demand has continued to increase. Water supply has been able to maintain water supply. Several service line repairs have been made in July, the supply lines only affect two customers at the most. The overall focus of Public Works has been maintaining water plant operation, and meter system repairs.

WORK ORDERS

Miscellaneous	2	Meter Accuracy	0
Water Quality	1	Low Pressure	0
Meter Swap	2	Leak	2
Occupant Change	5	Information	1
Repair	26	Disconnect	0
Connect	0	Cut off	1
Reinstate	0	Meter read	0
		TOTAL	40

Automated Meter Leak Notifications

61

Ryan Berry Water/Wastewater Superintendent



PUBLIC WORKS WASTEWATER REPORT

July 2026

In the month of July, the wastewater plant maintained TCEQ standards. The wastewater plant received a much needed repair in July. The plant is designed to have three blowers that provide air, and mechanical functions to the plant. The plant had only two operational blowers, CSS replaced the blower that was not operational, with a brand new set up, the plant is back to its original design. The repair gives the plant redundancy if one blower should go out.

Repairs to wastewater system:

New blower installed on wastewater plant.

Gallons pumped to Split Rail:

1.26 MG

A handwritten signature in blue ink, appearing to be "B. B. J.", is written over a horizontal line.

Water/Water Superintendent