



PUBLIC WORKS REPORT March 2026

WATER:

In the month of March, the water system operated in accordance with TECQ regulations. No major issues regarding the water distribution system. Watts Drilling has been contracted to refurbish the Trinity well at water plant 4 on Rim Rock Dr. Upon pulling the pump and pipe from the well, the existing pipe, pump motor, and the wire that supplies electricity were found to be in poor condition. All these components have been ordered and are scheduled to be installed at the beginning of April. No major repairs were required in the town’s distribution system. The Public Works crew added a new team member, Kevin Gunn, we are excited for the new addition.

WORK ORDERS

Miscellaneous	0	Meter Accuracy	0
Water Quality	0	Low Pressure	0
Meter Swap	0	Leak	0
Occupant Change	9	Information	1
Repair	2	Disconnect	0
Connect		Cut off	0
Reinstate	0	Meter read	0
		TOTAL	10

Automated Meter Leak Notifications	50
---	-----------

Ryan Berry Water/Wastewater Superintendent



PUBLIC WORKS WASTEWATER REPORT March 2026

In the month of March, the wastewater plant maintained TCEQ standards. In the Augusta lift station, a leak developed on the pipe that leaves the lift station that pumps to the wastewater plant. Repairs have been scheduled to replace the pipe inside the lift station. Repair is scheduled in the month of April.

Repairs to wastewater system:

Gallons pumped to Split Rail:

.887 MG

A handwritten signature in black ink, appearing to be "R. B. [unclear]", is written over a horizontal line.

Water/Water Superintendent