town of ANNETTA

PUBLIC WORKS REPORT
August 2026

WATER:

In the month of August the water system operated in accordance with TECQ regulations. In August, water demand has been high. The water system has been pushed hard, but we have been able to stay out of stage two water restrictions. Stage one water restrictions are voluntary. Going into the month of September, we will continue to monitor the water supply closely and determine if more action is needed.

WORK ORDERS

Miscellaneous	1	Meter Accuracy	0
Water Quality	2	Low Pressure	1
Meter Swap	1	Leak	0
Occupant Change	4	Information	3
Repair	22	Disconnect	0
Connect	0	Cut off	1
Reinstate	1	Meter read	1
		TOTAL	**37**

Automated Meter Leak Notifications	100

Ryan Berry Water/Wastewater Superintendent ----------

town of ANNETTA

PUBLIC WORKS WASTEWATER REPORT
August 2026

In the month of August, the wastewater plant maintained TCEQ standards. On the one hundred block of Lakeview, there was a manhole backed up. Town of Annetta had a jet truck come and clear the line. On the wastewater plant, we pulled and aerator, to see the condition, and also to get bids on repairing/replacing aerators on the plant. On the wastewater plant there are several aerators that are not functioning at one hundred percent. This is a preventative measure, but also is geared toward protecting the Town's investment in the wastewater plant.

Repairs to wastewater system:
New blower installed on wastewater plant.

Gallons pumped to Split Rail:

1.32

_____ Water/Water Superintendent