



PUBLIC WORKS REPORT

November 2025

WATER:

In the month of November, the water system operated in accordance with TECQ regulations. Annetta underwent its biannual inspection from TCEQ on the water system. No major violations were found. A lightning strike at the water tower damaged the town's Scada system. The new Scada system was already scheduled to be installed in December, and the amount of time to repair the outgoing equipment would delay the installation of the new. The public works crew worked to make several water plants operational off pressure switches. This allowed the water distribution to operate without Scada. The new Scada is being installed currently.

A boring contractor struck an 8 inch water main on November 26 causing pressure to drop citywide. Public work personnel were able to isolate the affected area and alongside Tejas contractors were able to make repairs to the line. A water service line was also repaired in the 100 block of St. Andrews.

WORK ORDERS:

Miscellaneous	0	Meter Accuracy	0
Water Quality	0	Low Pressure	0
Meter Swap	7	Leak	2
Occupant Change	9	Information	0
Repair	85	Disconnect	1
Connect	4	Cut off	0
Reinstate	0	Meter read	0
		TOTAL	108

Automated Meter Leak Notifications

55

Ryan Berry Water/Wastewater Superintendent





PUBLIC WORKS WASTEWATER REPORT

November 2025

In the month of November, the wastewater plant operated as normal and required no repairs. Lift stations also have been operating normally with no issues in November. One repair to a sewer collection line had to be made in the 100 block of Lakeview Dr.

Repairs to wastewater system:

Repair made to wastewater collection line

Gallons pumped to Split Rail:

1.05 MG

Water/Water Superintendent