



PUBLIC WORKS REPORT

October 2025

WATER:

During this month, the town's water system is currently operating within guidelines set forth by the TCEQ. The quarterly D.L.Q.R. was submitted to TCEQ. A leak repair was made by Tejas on the 100 block of St. Andrews. The internet fiber crews drilling slowed down significantly. Currently only one crew is active in the Meadow Park area of town. At the end of October, we welcomed a new member to our public works crew. The public works crew is gearing up for Zenner to come and help troubleshoot issues with our meter system. We expect them in town, by the end of October. The water system has been operating as normal.

WORK ORDERS:

| | | | |
|-----------------|---|----------------|-----------|
| Miscellaneous | 0 | Meter Accuracy | 0 |
| Water Quality | 0 | Low Pressure | 0 |
| Meter Swap | 0 | Leak | 1 |
| Occupant Change | 1 | Information | 0 |
| Repair | 2 | Disconnect | 0 |
| Connect | 1 | Cut off | 0 |
| Reinstate | 0 | Meter read | 2 |
| | | TOTAL | 41 |

Automated Meter Leak Notifications

58

Ryan Berry Water/Wastewater Superintendent



PUBLIC WORKS WASTEWATER REPORT

October 2025

In the month of October, the wastewater plant and system remained in compliance with TCEQ standards and regulations. The wastewater plant is operating normally. The loaner pump in the lift station on Augusta had an electrical short on October the 13th. Magnaflow was called and transferred the wastewater from that lift station to another manhole in the collection system. This continued until Monday the 20th. The two pumps approved by council were installed and the lift station returned to normal operating status.

Repairs to wastewater system:

New pumps installed in Augusta lift station.

Gallons pumped to Split Rail:

1.74 MGD

 Water/Water Superintendent