



## PUBLIC WORKS REPORT January 2026

**WATER:**

In the month of January, the water system operated in accordance with TECQ regulations. The new Scada System has been completed 90%. The public works crew made repairs to service lines in the 100 Block of Deer Creek drive have been made. There was a power outage that affected the water system on January 23, the backup generators turned on preformed as they should. Freezing weather moved through North Texas. The water system has been winterized and only suffered minor freezing in isolated parts of the water plants.

**WORK ORDERS:**

Miscellaneous	1	Meter Accuracy	0
Water Quality	0	Low Pressure	0
Meter Swap	2	Leak	2
Occupant Change	0	Information	0
Repair	24	Disconnect	0
Connect	1	Cut off	0
Reinstate	0	Meter read	0
		<b>TOTAL</b>	<b>30</b>

<b>Automated Meter Leak Notifications</b>	22
---	----

Ryan Berry Water/Wastewater Superintendent



## PUBLIC WORKS WASTEWATER REPORT January 2026

In the month of January, the wastewater plant maintained TCEQ standards. Lift stations needed no repairs and remained in good working order. In the 100 Block of Lakeview Dr. a manhole experienced a backup. The sewer main was jetted and the blockage was cleared.

### Repairs to wastewater system:

Sewer main Jetted for Blockage.

### Gallons pumped to Split Rail:

1.07 MG

A handwritten signature in blue ink, appearing to be "J. B. ...", is written over a horizontal line.

Water/Water Superintendent